



## **Summary of HUD's Lead Safe Housing Rule**

### Lead-Based Paint Regulations Changes

On September 15, 1999, HUD issued a new Federal lead-based paint regulation implementing Title X of the Housing and Community Development Act of 1992. This regulation makes many important changes in the lead-based paint requirements applicable to housing funded through HUD's Community Planning and Development (CPD) programs. State and local jurisdictions that receive funding from the Community Development Block Grant (CDBG) Program, HOME Program, McKinney Act homeless programs and other CPD programs.

Review the attached summary tables and documents that briefly explain the lead-based paint regulation requirements.

1. Summary of lead-based paint requirements by activity.
2. Four approaches to implementing lead hazard evaluation and reduction.
3. "Lead Speak"—A short glossary of commonly referred to lead-based paint terms.



**SUMMARY OF LEAD-BASED PAINT REQUIREMENTS BY ACTIVITY**

	Homeowner and Rental Rehabilitation (Subpart J)			Tenant Based Rental Assistance (TBRA) (Subpart M)	Acquisition only and Homebuyer (Subpart K)
	<\$5,000	\$5,000 - \$25,000	>\$25,000		
<b>Approach to Lead Hazard Evaluation and Reduction</b>	1. Do no harm	3. Identify and control lead hazards	4. Identify and abate lead hazards	2. Identify and stabilize deteriorated paint	2. Identify and stabilize deteriorated paint
<b>Notification</b>	Yes	Yes	Yes	Yes	Yes
<b>Lead Hazard Evaluation</b>	Paint Testing	Paint Testing and Risk Assessment	Paint Testing and Risk Assessment	Visual Assessment	Visual Assessment
<b>Lead Hazard Reduction</b>	Repair surfaces disturbed during rehabilitation	Interim Controls	Abatement (Interim Controls on exterior surfaces not disturbed by rehabilitation)	Paint Stabilization	Paint Stabilization
	Safe work practices Clearance	Safe work practices Clearance	Safe work practices Clearance	Safe work practices Clearance	Safe work practices Clearance
<b>Ongoing Maintenance</b>	For HOME rental only	For HOME rental only	For HOME rental only	Yes	Yes (if ongoing relationship)
<b>Response to poisoned children</b>	No	No	No	Yes	No
<b>Options</b>	Presume lead-based paint Use safe work practices on all surfaces	Presume lead-based paint and/or hazards Use standard treatments	Presume lead-based paint and/or hazards Abate all applicable surfaces	Test deteriorated paint. Use safe work practices only on lead-based paint surfaces.	Test deteriorated paint. Use safe work practices only on lead-based paint surfaces.



**FOUR APPROACHES TO IMPLEMENTING  
LEAD HAZARD EVALUATION AND REDUCTION**

<b>APPROACH 1. DO NO HARM</b>		
<b>Lead Hazard Evaluation</b>	<b>Lead Hazard Reduction</b>	<b>Options</b>
<p><b>Paint testing</b> performed on surfaces to be disturbed.</p>	<p>Repair surfaces disturbed during work.</p> <p><b>Safe work practices</b> used when working on areas identified as lead-based paint.</p> <p><b>Clearance</b> performed</p>	<p><b>Presume lead-based paint</b> is present and use safe work practices on all surfaces being disturbed.</p>
<b>APPROACH 2. IDENTIFY AND STABILIZE DETERIORATED PAINT</b>		
<b>Lead Hazard Evaluation</b>	<b>Lead Hazard Reduction</b>	<b>Options</b>
<p><b>Visual assessment</b> performed to identify deteriorated paint.</p>	<p><b>Paint stabilization</b> of identified deteriorated paint.</p> <p><b>Safe work practices</b> used.</p> <p><b>Clearance</b> performed.</p>	<p><b>Perform paint testing</b> on deteriorated paint. Safe work practice requirements only apply to lead-based paint.</p>
<b>APPROACH 3. IDENTIFY AND CONTROL LEAD HAZARDS</b>		
<b>Lead Hazard Evaluation</b>	<b>Lead Hazard Reduction</b>	<b>Options</b>
<p><b>Paint testing</b> performed on surfaces to be disturbed.</p> <p><b>Risk assessment</b> performed on entire dwelling.</p>	<p><b>Interim controls</b> performed on identified hazards.</p> <p><b>Safe work practices</b> used.</p> <p><b>Clearance</b> performed.</p>	<p>Presume lead based paint and/or lead based paint hazards are present and perform <b>standard treatments</b>.</p>
<b>APPROACH 4. IDENTIFY AND ABATE LEAD HAZARDS</b>		
<b>Lead Hazard Evaluation</b>	<b>Lead Hazard Reduction</b>	<b>Options</b>
<p><b>Paint testing</b> performed on surfaces to be disturbed.</p> <p><b>Risk assessment</b> performed on entire dwelling.</p>	<p><b>Abatement</b> performed on identified hazards.</p> <p><b>Interim controls</b> performed on identified hazards on the exterior that are not disturbed by rehabilitation.</p> <p><b>Safe work practices</b> used.</p> <p><b>Clearance</b> performed.</p>	<p>Presume lead-based paint and/or lead-based paint hazards are present and perform <b>abatement on all applicable surfaces</b> – deteriorated, impact, friction, chewable surfaces, and surfaces to be disturbed.</p>



## “LEAD SPEAK” – A BRIEF GLOSSARY COMMON LEAD-BASED PAINT TERMS

**Lead-Based Paint:** Paint or other surface coatings that contain lead equal to or exceeding 1.0 milligram per square centimeter or 0.5 percent by weight or 5,000 parts per million (ppm) by weight.

**Lead-Based Paint Hazards:** Any condition that causes exposure to lead from dust-lead hazards, soil-lead hazards, or lead-based paint that is deteriorated or present in chewable surfaces, friction surfaces, or impact surfaces, and that would result in adverse human health effects.

**Visual Assessment:** A visual inspection of interior and exterior surfaces to identify specific conditions that may be lead-based paint hazards. A visual inspection does not identify lead-based paint. The assessment may be performed by a person trained in visual assessment. Training for visual assessment is available on HUD’s website at [www.hud.gov/lead](http://www.hud.gov/lead).

### LEAD HAZARD EVALUATION

**Paint Testing:** Testing of specific surfaces, by XRF (x-ray fluorescence) or lab analysis, to determine the lead content of these surfaces, performed by a certified lead-based paint inspector or certified risk assessor.

**Lead-Based Paint Inspection:** A surface-by-surface investigation to determine the presence of lead-based paint and the provision of a report explaining the results of the investigation. It is performed by a certified paint inspector or risk assessor.

**Risk Assessment:** A comprehensive evaluation for lead-based paint hazards that includes paint testing, dust and soil sampling, and a visual evaluation. The risk assessment report identifies lead hazards and appropriate lead hazard reduction methods. A certified risk assessor must conduct the assessment.

**Lead Hazard Screen:** A limited risk assessment activity that can be performed instead of a risk assessment in units that meet certain criteria (e.g. good condition). The screen must be performed by a certified risk assessor. If the unit fails the lead hazard screen, a full risk assessment must be performed.

**Clearance Examination:** Clearance is performed after hazard reduction, rehabilitation or maintenance activities to determine if a unit is safe for occupancy. It involves a visual assessment, analysis of dust samples, and preparation of report. The certified risk assessor, paint inspector, or lead sampling technician (called a clearance technician in the HUD regulation) performing clearance must be independent from the entity/individual conducting paint stabilization or hazard reduction.

### LEAD HAZARD REDUCTION

**Paint Stabilization:** An interim control method that stabilizes painted surfaces and addressed the underlying cause of deterioration. Steps include repairing defective surfaces, removing loose paint and applying new paint.

**Interim Controls:** Set of measures to temporarily control lead-based paint hazards. Interim control methods must be completed by qualified workers using safe work practices. Follow-up monitoring is needed.

**Safe Work Practices:** Safe work practices are defined in HUD regulations at [24 CFR 35.1350](http://www.ecfr.gov/current/title-24/chapter-I/subchapter-B/part-35/subpart-1350).

**Standard Treatments:** A complete set of interim control methods that when used together temporarily control all potential lead hazards in a unit. Because they address all conditions, a risk assessment or other evaluation is not needed. Standard treatments must be completed by qualified workers using safe work practices. As with interim controls, follow-up monitoring is needed.

**Abatement:** Measures to permanently control (i.e., 20 years or more) lead-based paint or lead-based paint hazards. EPA regulations exclude from the definition of abatement “renovation, remodeling, landscaping or other activities, when such activities are not designed to permanently eliminate lead-based paint hazards, but instead are designed to repair, restore, or remodel a given structure or dwelling, even though these activities may incidentally result in a reduction or elimination of lead-based paint hazards.” [40 CFR 745.223]



## LEAD POISONING

**Environmental Intervention Blood Lead Level:** The level of lead in blood that requires intervention in a child under age six. This is defined as a blood lead level of 20  $\mu\text{g}/\text{dL}$  (micrograms per deciliter) of whole blood or above for a single test, or blood lead levels of 15-19  $\mu\text{g}/\text{dL}$  in two tests taken at least three months apart.

## KEY UNITS OF MEASUREMENT

**$\mu\text{g}$  (Microgram):** A microgram is  $1/1000^{\text{th}}$  of a milligram (or one millionth of a gram). To put this unit into perspective, a penny weighs 2 grams. To get a microgram, you would need to divide the penny into 2 million pieces. A microgram is one of those two million pieces.

**$\text{ft}^2$  (Square foot):** One square foot is equal to an area that has a length of one foot (12 inches) and a width of one foot (12 inches).

**$\mu\text{g}/\text{dL}$ :** Micrograms per deciliter used to measure the level of lead in children's blood to establish whether intervention is needed. A deciliter ( $1/10^{\text{th}}$  of liter) is a little less than half a cup. As noted above, a microgram is the same weight as one penny divided into two million parts.

**$\mu\text{g}/\text{gram}$ :** Micrograms per gram of sample, equivalent to parts per million (ppm) by weight. Used to measure lead in soil.

**$\mu\text{g}/\text{ft}^2$ :** Micrograms per square feet is the measurement used to measure levels of lead in dust samples. The clearance report should have the dust sampling results listed in  $\mu\text{g}/\text{ft}^2$  (micrograms per square foot).

**$\text{mg}/\text{cm}^2$ :** Milligrams per square centimeter. Used to measure lead in paint.

**percent:** Percent by weight, used usually for lead-based paint (1 percent = 10,000  $\mu\text{g}/\text{gram}$ )

**ppm:** Parts per million by weight, equivalent to  $\mu\text{g}/\text{gram}$  (10,000 ppm = 1 percent). Used to measure lead in paint and soil.

## LEAD-BASED PAINT STANDARDS

### Paint – Definition of Lead-Based Paint

Paint or other surface coatings that contain at least:

- 1 milligram per centimeters square ( $\text{mg}/\text{cm}^2$ ) of lead;
- 0.5 percent lead; or 5,000 parts per million lead by dry weight.

\*In 1978 the Consumer Product Safety Commission banned the residential use of lead-based paint that contained greater than or equal to 0.06 percent or 600 ppm of lead.

### Dust – Federal Thresholds for Lead-Contamination (Risk Assessment/Clearance)

- |                                   |                                 |
|-----------------------------------|---------------------------------|
| ➤ Floors                          | 40 $\mu\text{g}/\text{ft}^2$    |
| ➤ Interior windowsills            | 250 $\mu\text{g}/\text{ft}^2$   |
| ➤ Window troughs (Clearance only) | 400 $\mu\text{g}/\text{ft}^2$ * |

### Soil – Federal Thresholds for Bare Soil Contamination

- |   |                              |
|---|------------------------------|
| ➤ Play areas used by children under the age of 6                                    | 400 $\mu\text{g}/\text{g}$   |
| ➤ Other areas, if more than 9 $\text{ft}^2$ in total area of bare soil per property | 1,200 $\mu\text{g}/\text{g}$ |